

## **Water Quality**

### **West Public Water System – West of Nashua Ave**

Iron – 0.4 mg/L

Manganese – 0.3 mg/L

Total Hardness 300 mg/L or 18 grains per gallon

### **East Public Water System – East of Nashua Ave**

Iron – 0.8 mg/L

Manganese – 0.1 mg/L

Total Hardness 222 mg/L or 13 grains per gallon